
Inspectors Panel Discussion Regional Inspectors Brenda Hayward, Doug Smith, Jay Baas Subsurface Bureau, Land Resources Management

INSPECTORS ON PANEL douglas.smith@des.nh.gov piohn.baas@des.nh.gov brenda.hayward@des.nh.gov 893-3637 559-1511 brenda.hayward@des.nh.gov 875-7730

INSTALLATION TOPICS PIPES TANK - BAFFLES - FILTER VENTING STONE + PIPE SYSTEMS ENVIRO AND ADVANCED TAGS PIPE CONFIGURATION ENVIRO




















































































Last years Discussion

- On replacement inspections often we only see the new EDA. The plan does not specify that any work is needed for the tank or in some cases the tank, pump chamber or grease trap.
- In these cases plans are vague on the tank condition and it is clear that the tank has not been recently uncovered
- This concerns us SOLUTIONS:

Feedback

- Should we require the designer to verify all tank issues on the plan at design stage?
- Should we require the installer to verify tank integrity, baffles etc (note for file?)
- Or should a policy be put in place for the tank inlet, outlet etc be open for this type of inspection



| _ | | | |
|---|--|--|--|
| _ | | | |
| _ | | | |
| | | | |
| | | | |
| _ | | | |
| _ | | | |
| | | | |

| QUESTIONS | |
|-----------|--|
| | |